

## 試驗報告



報告編號：TB-19-04190  
C-19-10228

頁數：1 OF 1

報告日期：108年07月24日


工程名稱：自測  
 承包商：-----  
 委託單位：國宇建材股份有限公司  
 供料廠商：國宇建材股份有限公司  
 樣品名稱：國宇輕質磚ALC白磚  
 加註項目：2.5分螺絲+4.5分壁虎  
 取樣人員：國宇建材股份有限公司-廖建榮  
 送驗人員：國宇建材股份有限公司-廖建榮  
 會驗人員：國宇建材股份有限公司-廖建榮  
 取樣日期：108年06月26日  
 收件日期：108年07月02日  
 試驗日期：108年07月02日~108年07月24日  
 會驗日期：108年07月19日  
 備註：

- 1.以上資料由顧客提供(收件及試驗日期除外)
- 2.除非另有說明，此報告結果僅對測試之樣品負責  
未經本公司事先書面同意，此報告不可部分複製
- 3.下述報告內容標示#處由顧客提供
- 4.本樣品由SGS材料暨工程實驗室-斗六(申請書號碼：DB-19-01867 C-19-05339，  
收件日期：108年06月26日)轉送至本實驗室執行本報告所示之試驗項目。

### 試驗結果：

試驗項目	試驗結果	試驗方法
吊掛力 (kgf)	522	將樣品固定於30頓萬能試驗機上，以每秒0.5 kgf/cm <sup>2</sup> 之速率垂直加壓於樣品之螺釘上，求得最大破壞荷重

註：以下為樣品試驗前及試驗後照片



試驗前



試驗後

*謝男銀*  
 報告簽署人

本報告若有提供規範值時，該規範值僅供參考，合格之判定以委託單位實際要求為準

This document is issued by the Company subject to its General Conditions of Service printed overleaf, available on request or accessible at <http://www.sgs.com/en/Terms-and-Conditions.aspx> and, for electronic format documents, subject to Terms and Conditions for Electronic Documents at <http://www.sgs.com/en/Terms-and-Conditions/Terms-e-Document.aspx>. Attention is drawn to the limitation of liability, indemnification and jurisdiction issues defined therein. Any holder of this document is advised that information contained hereon reflects the Company's findings at the time of its intervention only and within the limits of Client's instructions, if any. The Company's sole responsibility is to its Client and this document does not exonerate parties to a transaction from exercising all their rights and obligations under the transaction documents. This document cannot be reproduced except in full, without prior written approval of the Company. Any unauthorized alteration, forgery or falsification of the content or appearance of this document is unlawful and offenders may be prosecuted to the fullest extent of the law. Unless otherwise stated the results shown in this test report refer only to the sample(s) tested.

## 試驗報告



報告編號：TB-19-04191  
C-19-10229

頁數：1 OF 1

報告日期：108年07月24日

工程名稱：自測  
 承包商：-----  
 委託單位：國宇建材股份有限公司  
 供料廠商：國宇建材股份有限公司  
 樣品名稱：國宇輕質磚ALC白磚  
 加註項目：3.5分螺絲+5.5分壁虎  
 取樣人員：國宇建材股份有限公司-廖建榮  
 送驗人員：國宇建材股份有限公司-廖建榮  
 會驗人員：國宇建材股份有限公司-廖建榮  
 取樣日期：108年06月26日  
 收件日期：108年07月02日  
 試驗日期：108年07月02日~108年07月24日  
 會驗日期：108年07月19日  
 備註：

- 1.以上資料由顧客提供(收件及試驗日期除外)
- 2.除非另有說明，此報告結果僅對測試之樣品負責  
未經本公司事先書面同意，此報告不可部分複製
- 3.下述報告內容標示#處由顧客提供
- 4.本樣品由SGS材料暨工程實驗室-斗六(申請書號碼：DB-19-01867 C-19-05339，  
收件日期：108年06月26日)轉送至本實驗室執行本報告所示之試驗項目。


### 試驗結果：

試驗項目	試驗結果	試驗方法
吊掛力 (kgf)	502	將樣品固定於30頓萬能試驗機上，以每秒0.5 kgf/cm <sup>2</sup> 之速率垂直加壓於樣品之螺釘上，求得最大破壞荷重


註：以下為樣品試驗前及試驗後照片



試驗前



試驗後

  
 報告簽署人

本報告若有提供規範值時，該規範值僅供參考，合格之判定以委託單位實際要求為準

This document is issued by the Company subject to its General Conditions of Service printed overleaf, available on request or accessible at <http://www.sgs.com/en/Terms-and-Conditions.aspx> and, for electronic format documents, subject to Terms and Conditions for Electronic Documents at <http://www.sgs.com/en/Terms-and-Conditions/Terms-e-Documents.aspx>. Attention is drawn to the limitation of liability, indemnification and jurisdiction issues defined therein. Any holder of this document is advised that information contained hereon reflects the Company's findings at the time of its intervention only and within the limits of Client's instructions, if any. The Company's sole responsibility is to its Client and this document does not exonerate parties to a transaction from exercising all their rights and obligations under the transaction documents. This document cannot be reproduced except in full, without prior written approval of the Company. Any unauthorized alteration, forgery or falsification of the content or appearance of this document is unlawful and offenders may be prosecuted to the fullest extent of the law. Unless otherwise stated the results shown in this test report refer only to the sample(s) tested.